




Weld on Crosses

Schedule 40/Std Wall, Carbon Steel

Inches / Pounds



Part #	Nominal Pipe Size	Outside Diameter	Inside Diameter	Wall Thickness	Center to End of Run (C)	Center to End of Branch (M)	Pipe Schedule	Approximate Weight (in Lbs.)
KWC1.25	1 1/4	1.660	1.442	0.109	1.88	1.88	40	1.5
KWC1.5	1 1/2	1.900	1.610	0.145	2.25	2.25	40	2.3
KWC2	2	2.375	2.067	0.154	2.50	2.50	40	3.4
KWC2.5	2 1/2	2.875	2.469	0.203	3.00	3.00	40	5.9
KWC3	3	3.500	3.068	0.216	3.38	3.38	40	8.3
KWC4	4	4.500	4.026	0.237	4.13	4.13	40	13.9
KWC5	5	5.562	5.046	0.258	4.88	4.88	40	21.6
KWC6	6	6.625	6.109	0.258	5.63	5.63	40	31.5
KWC8	8	8.625	7.981	0.322	7.00	7.00	40	57.1
KWC10	10	10.75	10.020	0.365	8.50	8.50	40	96.0
KWC12	12	12.75	12.000	0.375	10.00	10.00	40	139.0
KWC14	14	14.000	13.250	0.375	11.00	11.00	STD	168.0
KWC16	16	16.000	15.250	0.375	12.00	12.00	STD	216.0
KWC18	18	18.00	17.250	0.375	13.50	13.50	STD	278.0
KWC20	20	20.00	19.250	0.375	15.00	15.00	STD	348.0
KWC24	24	24.00	23.250	0.375	17.00	17.00	STD	488.0

** Dimensions conform to ASME B16.9 & material conforms to ASTM SA-234 Grade B*